

Translated Version
Government of Karnataka
Department of Public Works,
Office of the Executive Engineer, Special division, Nazarbad, Mysuru
E-mail: eepwdspecialmysuru@gmail.com Phone No. & Fax No 08212492297

No.EE:PWD:VVNo-2 Building Safety:2021-22

Date:

884-85

04/09/21

To,

The Secretary,
DayanandaAryaVidya Public School,
Vishweshwaranagar,
Mysuru

Dear Sir,

Subject: Regarding issue of Building safety certificate for Building of
DayanandaAryaVidya Public School, Vishweshwaranagar

Mysuru.

Reference: 1) Date of appeal letter 21-06-2021

- 2) Assistant Executive Engineer, Department of Public Works, No.1, Special Sub division,
Mysuru, Vide letter No. 345, Dated
09-08-2021.

Regarding the above matter, that in your letter of reference (1) you have requested to issue a safety certificate for the School building of DayanandaAryaVidya Public School building has been submitted by the Assistant Executive Engineer, Department of Public Works, No.1, Special Sub Division, Mysore in reference (2) letter in the prescribed form.

The Building of AryaVidya Public School at Vishweshwaranagar, Mysuru was jointly inspected on date 30-07-2021 by Assistant executive Engineer, Department of Public Works, No-1, Special Sub division, Mysuru, along with AryaVidya Public School and Education Department Officials, and observed that the building is in good condition.

The building has ground + 3 floors and the ceiling height of Ground floor, First floor and Second floor of the said building is 3.60 meters. And the ceiling height of the Third floor is found to be 3.70 meters. Toilet and drinking water facility is provided in the said building.


Further, regarding the safety of the building, The Assistant Executive Engineer, Public Work Department, No-1, Special Sub Division, Mysuru, has stated regarding concrete soundness of the building in reference letter dated 28-08-2021, Vidyavardhaka College of Engineering, Mysuru, tested with a Non-destructive Digital indicating Tester and Physical Observation & Accordingly necessary field tests, the building is found to be sound as per the test report carried out by the technical team of the Sub-division along with the consultant. The conclusion report given by the said organizations is as follows:

Sl. No. 23 Vol No. 05 Date 22 JAN 2024
No. of Corrections 02

22 JAN 2024

NOTARY
A.M SUMITHRA
B.A., LL.B.
MYSORE CITY
Reg. No. 7974
DATE OF EXPIRY
02/06/2025
TRANSLATED this document from
the original in Kannada language to
English and translation verified by me
NOTARY MYSORE

- **Ultrasonic Pulse Velocity Test**
Conducting Ultrasonic pulse velocity test for compressive strength of in-situ concrete on Columns, Beams and slab at Critical points using "PUNDIT 6" (Portable ultrasonic non-destructive Digital Tester) carried out by Vidyavardhaka College of Engineering, Mysore, with Technical Team of Public Work Department. The building appears to be of good quality.
Recognizance, visual inspection of Building-cracks, distress, dampness etc., tested by Vidyavardhaka College of Engineering, Mysore with Technical team of Department of Public Works. The building appears to be of good quality.
- M/s Rao Associates (Sri Yogesh Rao D V) Mysore certified that the building is built as per the norms of National Building code of India 2016, and is safe.
- M/s Rao Associates (Sri Yogesh Rao D V) Mysore has issued Form for Certificate for Structural Design Sufficiency Certificate as per National Building Code of India 2016.
- Considering all the documents given by the said organisation and considering the certificates issued by Vidyavardhaka College of Engineering, Mysuru that the building is structurally safe and the technical team of Public Works Department has inspected the building and it has been found from the test reports that the building is "Structurally stable". It is considered that the building is constructed as per the approved Blue Print and considering that the building is "Structurally stable", Building Safety Certificate is issued for a period of five years from the current year 2021-22.
- Further, with regard to the fire Safety of the said building, this Safety certificate is issued for the said School Building, that the conditions imposed by the Department are fulfilled.



Executive Engineer,
Department of Public Works,
Special division,
Mysuru.

TRANSLATED this document from
the original in Kannada language to
English and translation verified by me
[Signature]
NOTARY MYSORE

Note: Since all the Government Orders have been issued in Kannada (Original transaction) language as per the decision taken by cabinet of Karnataka Government, this translation of the order is made in English

No. of Corrections..... *[Signature]*

Sl. No. *23* Vol No. *01*
Page No. *05* Date *22 JAN 2024*