

Translated Version
Government of Karnataka
Department of Public Works,
Office of the Executive Engineer, Special Division, Nazarbad, Mysuru
E-mail: eepwdespecialmysuru@gmail.com Phone No & Fax No 0821-2492297

No. EE:PWD:VVNo-2 Building Safety:- 2021-22

Date:- 884-85

04/09/2021

To,
The Secretary,
Dayananda Arya Vidya Public School,
Vishweshwaranagar,
Mysuru.

Dear Sir,

Subject:- Regarding issue of Building safety certificate for building of Dayananda Arya Vidya Public School, Vishweshwaranagara. Mysuru.

Reference : 1) Date of appeal letter 21-06-2021

2) Assistant Executive Engineer, Department of Public Works,
No.1 Special Sub division, Mysuru, Vide letter No. 345


Dated :09/08/2021

Regarding the above matter, that in your letter of reference (1) you have requested to issue a safety certificate for the school building of Dayananda Arya Vidya Public School building has been submitted by the Assistant Executive Engineer, Department of Public works, No.1, Special Sub Division, Mysore in reference (2) letter in the prescribed form.

The Building of Dayananda Arya Vidya Public School at Vishweshwaranagar, Mysuru was jointly inspected on date:30-07-2021 by Assistant executive Engineer, Department of Public Works, Department Officials, and observed that the building is in good condition.

The building has ground +3 floors and the ceiling height Ground floor, First floor and second floor of the said building is 3.60 meters. And the ceiling height of the third floor is found to be 3.70 meters. Toilet and drinking water is provided in the said building.

Further, regarding the safety of the building. The Assistant Executive Engineer, Public Work Department, No-1 Special Sub Division, Mysuru, has stated regarding concrete soundness of the building in reference letter dated 28-08-2021, Vidyavardhaka college of Engineering, Mysuru tested with a Non – destructive Digital indicating Tester and Physical observation & Accordingly necessary field tests, the building is found to be sound as per the test report carried out by the technical team of the Sub – division along with the consultant. The conclusion report given by the said organization is as follows:



Translated Kannada to
English
K.V. VASU
ADVOCATE & NOTARY
1407 7th Main
Vishwanandanagara

- **Ultrasonic Pulse Velocity Test**

Conducting Ultrasonic Pulse Velocity Test for compressive strength of in-situ concrete on columns. Beams and slab at critical points using "PUNDIT 6" (Portable Ultrasonic non-destructive Digital Tester) carried out by Vidyavardhaka College of Engineering, Mysore with Technical team of Department of Public Works. The building appears to be of good quality.

Recognizance, visual inspection of building – cracks, distress, dampness etc., tested by Vidyavardhaka College of Engineering, Mysore with Technical team of Department of Public Works. The building appears to be of good quality.

- M/s Rao Associates (Sri Yogesh Rao D V) Mysore certified that the building is built as per the norms of National Building code of India 2016, and is safe.
- M/s Rao Associates (Sri Yogesh Rao D V) Mysore has issued form for Certificate for Structural Design Sufficiency Certificate as per National Building Code of India 2016.
- Considering all the documents given by the said organization and considering the certificates issued by Vidyavardhaka College of Engineering, Mysuru that the building is structurally safe and the technical team of Public Works Department has inspected the building and it has been found from the test reports that the building is "Structurally Stable". It is considered that the building is constructed as per the approved blue print and considering that the building is "Structurally stable", Building Safety Certificate is issued for a period of five years from the current year 2021-22, 2022-23, 2023-24, 2024-25, 2025-26.
- Further with regard to the fire safety of the said building, this safety certificate is issued for the said School Building, that the conditions imposed by the Department are fulfilled.

Executive Engineer,
Department of Public Works,
Special Division, Mysuru.

TRUE COPY
Compared with the Original
and Found Correct

[Signature]
Notary Mysore District

Note:- Since all the Government Orders have been issued in Kannada (Original Transaction) language as per the decision taken by cabinet of Karnataka Government, this translation of the order is made in English.



[Signature]
K.V. VASU
ADVOCATE & NOTARY
1407, 7th Main
Vivekanandanagar,
Mysuru-570023
Mob: 934173661

[Signature]
K.V. VASU
ADVOCATE & NOTARY
1407, 7th Main
Vivekanandanagar,
Mysuru-570023
Mob: 934173661